

FlexRight™ - Quick Start - Installation Instructions

*Save energy - improve airflow - eliminate kinks and restrictions - form 90-degree flexible duct elbows – sizes 4” - 16”
Install FlexRight at: Diffusers - Grilles - Registers - Duct take-offs / taps - HVAC equipment round inlets and outlets.*

1. Connect flexible duct inner core to air device per flexible duct manufacturer's installation instructions.
2. Pull flexible duct insulation and outer jacket over core.
3. Thread cable ties through both FlexRight saddle bands. (Fig #1) (Cable ties not included.)
4. Position FlexRight durable elbow support under flexible duct to form 90-degree elbow. (Fig #2)
5. Using cable tie tensioning tool, tighten cable tie around neck of air device to secure FlexRight.
6. Fasten second cable tie loosely around flexible duct. Do not over-tighten and crush flexible duct.
7. Cut-off and discard excess from both cable tie ends.
8. Alternate installation. (Fig #3)

